

ADDENDUM #2
INVITATION FOR BIDS R-32
WINTER ISLAND SCENIC TRAIL
OCTOBER 27, 2015

- 1. Are all roads on Winter Island accessible access for trucks and machinery?**

Site roads are more narrow than standard highway width but are accessible for trucks and machinery.

- 2. There is a concrete base near the harbormasters quarters that is very large and on higher grade, but not mentioned in the plan, it seems to be at or near the proposed sidewalk? The entire area adjacent to the asphalt road is extremely high.**

The grade should be built to cover this foundation.

- 3. Can some existing loam (recovered on-site) be reused?**

Yes, as long as the loam recovered on-site meets specifications.

- 4. Can Winter Island Park use the gathered bluestone processed gravel that is to be recovered from the tree alley?**

Assume that it will be removed off-site.

- 5. Does the Bio retention basin need a drain inlet or curb inlet?**

Drain inlet

- 6. Where does the exit pipe of the Bio retention basin lead?**

Outlet drains treated water to beach, about 34' away.